



## CITY OF MIAMI

### ADDENDUM NO. 4

February 12, 2009

### INVITATION TO BID NO. 08-09-021

### ATHALIE RANGE PARK FIELD IMPROVEMENTS B-39507

**TO: ALL PROSPECTIVE BIDDERS:**

The following changes, additions, clarifications, and/or deletions amend the above-captioned Bid/Contract documents, and shall become an integral part of the bid responses and the subsequent contract. Please note the contents herein and affix same to the documents you have on hand.

**Additional Information:**

There are two attachments included as part of this Addendum:

1. Geotechnical Report
2. Specification Section 11480-Bleachers.

Both are available as attachments on the CIP website.

**Request for Information:**

**Q1. Please provide concrete slab and footing for proposed bleachers?**

A1. The concrete slab shall be 6" slab with 6X6 W-2.9 X W2.9, WWF over well compacted fill. The slab shall extend beyond the bleachers to have 5 ft apron in front and 5 ft apron on back and 6 ft apron on each side; Bleacher pad shall slope to landscaped area at 1:50 max slope.

**Q2. Is Boring Test available?**

A2. Yes, geotechnical report is provided with this Addendum. Contractor shall be responsible for the verification of the information provided.

**Q3. Please provide specification for sports field equipment (baseball & soccer)?**

A3. Please note that the fields shall be Regulation Baseball and Regulation Football; See response no. A6 for additional information on equipment.

**Q4. Will the demo items marked "to be retained by owner" be removed from the site by the owner or delivered by the contractor? If delivered, to what site and offloaded by the owner or contractor?**

**A4. City will coordinate move of items to be retained by owner.**

**Q5. Is the contractor responsible for stripping of the football field lines as well as the soccer field lines?**


**A5. The contractor shall be responsible for all stripping as specified on plans; Provide dry line marking -standard field paint.**

**Q6. There are no specifications in the bid documents for the following items: Aluminum football goals, football portable team benches, football bleachers, baseball bleachers and dugout benches. Please provide manufacturer and model numbers.**

**A6. Provide the following equipment:**

1. Football goalpost shall be removable, aluminum with powder coated finish; cap flag attachment and windflag model no. WS3D; 18" thick vinyl encased goalpost pads(6'-0" high) Sportsedge Model SEF305 OR approved equal. See sheet C-10. Contractor shall install per manufacturer's instructions; Manufacturer to submit foundations and calculation shop drawings for review;
2. Soccer Goal: as specified in sheet C-11.
3. Zone Pylons shall be Fischer standup pylons PY-1 (deluxe weighted pylon) or approved equal.
4. Portable Team Benches shall be Fischer AB -21 (21 foot bench, no back rest) or approved equal.
5. Football and Baseball bleacher manufacturer shall be Seating Solutions or approved equal. See sheet A1.3 for details and attached Spec Section 11480; Manufacturer to submit foundations and calculation shop drawings for review.
6. Dugout benches; Provide (2) 15 inch benches per dugout; Jaypro Model No. PBS-20 PC. Or approved equal; Install per manufacture's instruction for permanent installation.

**THIS ADDENDUM IS AN ESSENTIAL PORTION OF THE CONTRACT DOCUMENT AND SHALL BE MADE A PART THEREOF.**

  
\_\_\_\_\_  
Gary Fabrikant, Assistant Director  
Department of Capital Improvements Program

This addendum should be signed and dated by Bidder and submitted as proof of receipt with the submission of bids. The Bidder by identifying the addendum number in their bid proposal and by the signing and submission of their bid, shall serve as proof of receipt of this addendum.

NAME OF FIRM: \_\_\_\_\_  
SIGNATURE: \_\_\_\_\_  
DATE: \_\_\_\_\_